

July 3, 2025

ADDENDUM #2  
Southern Ute Indian Tribe - Utilities Division  
Northridge Sewer Main Improvement Project (Phase 1)

Bidders:

Addendum #2 has been prepared for the aforementioned project based on the following questions received to date.

1. Due to the complexity of this project, can the bid date be extended?
  - a. **The Project Bid Date is extended to July 22<sup>nd</sup>. The question deadline is extended to July 18<sup>th</sup>.**
2. Can a lower DR on the HDPE replacement pipe be used to facilitate a faster pipe bursting process by increasing safe pulling force?
  - a. **Replacement sewer pipe shall be minimum HDPE DR-17 IPS for all depths up to 20 feet and DR-15.5 IPS for depths over 20 feet. DR-15.5 HDPE pipe should be installed on the three runs between SSMH 07-29 and downstream to SSMH 07-03. Refer to updated Bid Form (Addendum #2).**
3. Is pipe bursting installation required for the locations shown on the construction plans, or will alternate installation methods be acceptable?
  - a. **Pipe bursting locations shown on the plans are for reference only. The utilities department is interested in the most cost-effective solution to repair the deficient sewer system.**

Bidders are reminded to acknowledge receipt of this Addendum #2 on the Bid form.

Sincerely,



---

Rob Harries PE  
Goff Engineering & Surveying, Inc.

Attachments:

1. Bid Form (Addendum #2)

| <b>BID FORM</b>  |             |             |                  |                  |
|--|-------------|-------------|------------------|------------------|
| <b>CONTRACT ITEM</b>   | <b>UNIT</b> | <b>Q'TY</b> | <b>Unit Cost</b> | <b>Extension</b> |
| MOBILIZATION / DEMOBILIZATION                                | LS          | 1           | \$ -             | \$ -             |
| HYDRO-EXCAVATION   | HR          | 120         | \$ -             | \$ -             |
| TRAFFIC CONTROL  | LS          | 1           | \$ -             | \$ -             |
| ASPHALT PATCHING (INCL. REMOVAL, DISPOSAL)                   | SY          | 530         | \$ -             | \$ -             |
| CONCRETE PATCHING (INCL. REMOVAL, DISPOSAL)                  | SF          | 5460        | \$ -             | \$ -             |
| FLOWABLE TRENCH BACKFILL                                     | CY          | 52          | \$ -             | \$ -             |
| 8" DR-17 IPS HDPE (INCL. TRENCH, BED, BACKFILL)              | LF          | 3010        | \$ -             | \$ -             |
| 8" DR-17 IPS HDPE (INCL. PIPE BURSTING INSTALLATION)         | LF          | 6790        | \$ -             | \$ -             |
| 8" DR-15.5 IPS HDPE (INCL. PIPE BURSTING INSTALLATION)       | LF          | 1200        | \$ -             | \$ -             |
| SAG REHABILITATION (0-10' DEPTH)                             | LF          | 310         | \$ -             | \$ -             |
| SAG REHABILITATION (10-20' DEPTH)                            | LF          | 330         | \$ -             | \$ -             |
| SAG REHABILITATION (20-30' DEPTH)                            | LF          | 80          | \$ -             | \$ -             |
| SALVAGE AND RECONSTRUCT EX. SSMH                             | EA          | 28          | \$ -             | \$ -             |
| RECONSTRUCT EX. SSMH BASE (AFTER PIPE BURSTING)              | EA          | 38          | \$ -             | \$ -             |
| FURNISH AND INSTALL NEW PRECAST SSMH W/ PREFABRICATED BASE   | EA          | 10          | \$ -             | \$ -             |
| 4" SDR-35 SEWER SERVICE TAP (INCL. TAP & EXCAVATION LABOR)   | EA          | 77          | \$ -             | \$ -             |
| 4" SDR-35 SEWER SERVICE PVC PIPE                             | LF          | 360         | \$ -             | \$ -             |
| CONCRETE MANHOLE COLLAR                                      | EA          | 10          | \$ -             | \$ -             |
| SEWER BYPASS PUMPING   | LS          | 1           | \$ -             | \$ -             |
| CLEARING AND GRUBBING (INCL. REMOVAL OF TREES, SHRUBS, ETC.) | LS          | 1           | \$ -             | \$ -             |
| HYDROSEEDING (UPLAND SEED MIX) (INCL. HYDRO MULCHING)        | AC          | 0.74        | \$ -             | \$ -             |
| SITE RESTORATION   | LS          | 1           | \$ -             | \$ -             |
| DEWATERING   | LS          | 1           | \$ -             | \$ -             |
| CONSTRUCTION SURVEY  | LS          | 1           | \$ -             | \$ -             |
| SWPPP IMPLEMENTATION AND ADMINISTRATION                      | LS          | 1           | \$ -             | \$ -             |
| QA/QC TESTING  | LS          | 1           | \$ -             | \$ -             |
| PRE-POST VIDEO INSPECTION                                    | LS          | 1           | \$ -             | \$ -             |
| TOTAL CONSTRUCTION COST                                      |             |             | \$               | -                |
| TERO FEE (4% OF CONSTRUCTION COST)                           |             |             | \$               | -                |
| <b>TOTAL BID PRICE</b>                                       |             |             | <b>\$</b>        | <b>-</b>         |